



# KERALA WATER AUTHORITY

## QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

### Test Report

Test Report. No : KWA/QCDL/TSR/7452/2024


Report Date : 04.10.2024

Customer Name & Address			1. Date of Receipt :28.09.2024	
St.Paul's Public School, Kurjachira,Mob:9495013151			2. Sampling done by : The Customer	
			3.UID No.of Sample: KWA/QCDL/TSR/S-007452/2024	
			4. Source of Sample : Bore Well	
			5.Sample condition : Good	
			6.Name of sample : Water	
			7. Purpose of test : Commercial	
			9. Sample Quantity :100ml	
			9. Test Performing Dates From :30.09.2024 To : 03.10.2024	
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	Not Detected
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - 1 : 2014	Not Detected

*Remarks:-Coliform and Ecoli bacteria not detected.*

*NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.*

Reviewed by:



Authorized By Ragesh M.K.   
Quality Manager,  
Quality Control District Laboratory  
Kerala Water Authority  
Thrissur - 680 905

KWA/QCDL/TSR-R-No:6	Issue No:2	Issue Date 10/01/2023
Rev.No: 00	Rev Date: 00	Page 1of 1

Manager  
St. PAUL'S PUBLIC SCHOOL  
KURIACHIRA



Principal  
ST. PAUL'S PUBLIC SCHOOL  
KURIACHIRA, THRISSUR-6.